

ColorGard® System Warranty Program: Inspection Criteria and Form

Job Name: _____

Address: _____

Roof Information

Manufacture and Panel Name: _____

Panel Info: _____

Inspection criteria for the following (as stated in Warranty Application Form section B)

Yes No

- Fully completed Warranty Application Form signed by Contractor?
- Evidence of a pending ColorGard Snow Retention System order or purchase form an authorized ColorGard Snow Retention System distributor?
- Printed copy of all calculations performed with Manufacturer's web calculator, bearing project name?
- Scale drawing showing layout of multiple rows?
- Received Issuance Fee for Manufacturer's Limited Warranty?
- Received signed copy of the ColorGard System Warranty Program Limited Warranty?

Field Inspection

Yes No

- Setscrew tension (24ga 130-150; 22ga 160-180 inch pounds) based on a random check?
- Rows of assembly match scale drawing?
- SnoClips installed correctly?
- SnoClips spaced adequately?
- ColorGard Splice installed between sections of ColorGard?
- Mounting Bolt tensioned to 42ft. lbs?
- The retainer lip of the ColorGard has been crimped to prevent Color Strip from moving?
- The ColorGard System does not cantilever from end clamp a distance of more that 6"?

